



- GENERAL NOTES**
1. ALL EXISTING PLUMBING AND PIPING WAS TAKEN FROM EXISTING DOCUMENTS. VERIFY EXISTING PIPE SIZES AND LOCATIONS PRIOR TO STARTING WORK.
 2. COORDINATE ALL WORK AND INTERRUPTIONS WITH THE OWNER PRIOR TO BEGINNING WORK.

- NEW WORK PLAN NOTES**
1. BALANCING VALVE.
 2. ASSE 1070 APPROVED MIXING VALVE.
 3. GAS PRESSURE REGULATING VALVE, INLET PRESSURE OF 2 PSI AND AN OUTLET PRESSURE OF 14" WC.
 4. GAS SOLENOID VALVE WITH MANUAL RESET CONNECTED TO THE FIRE ALARM SYSTEM, 120V, NORMALLY CLOSED.
 5. PROVIDE AN ELECTRIC TRAP PRIMER EQUAL TO SIOUX CHIEF 695-ES01 FOR FLOOR DRAIN.
 6. AIR COMPRESSOR PROVIDED BY OTHERS. REVIEW FINAL CONNECTIONS WITH MANUFACTURER.
 7. COORDINATE WITH ELECTRICAL FOR GENERATOR FINAL CONNECTION REQUIREMENTS PRIOR TO INSTALLATION.
 8. GAS PRESSURE REGULATING VALVE, INLET PRESSURE OF 2 PSI AND AN OUTLET PRESSURE OF 11" WC.

Stephen Boruff, AIA
Architects + Planners, Inc.
AAC 002226
Architecture
Planning
Interior Architecture

901
Northpoint Parkway
Suite 101
West Palm Beach
Florida 33407

J L R D JOHNSON, LEVINSON
BALAN, DAVILA, INC.
COMMERCIAL ARCHITECTS
1450 Centrepark Boulevard, Suite 350
West Palm Beach, Florida 33411
(561) 688-2303 (561) 688-2302 Fax
www.jlrldinc.com

Ruben Ortega Blanco, P.E. 90645
Ward C. Connors, P.E. 45639

New Kitchen
Facility for



701 Boutwell Road
Lake Worth, FL 33461



Project No. 22.046
24 February 2023
Bidding, Permit and
Construction

P
4
JLRD PROJECT NO:
122110