


- NOTES:
1. CONTRACTOR TO TIE LIGHTNING PROTECTION SYSTEM TO STEEL COLUMNS WHERE APPLICABLE.
 2. CONTRACTOR TO CONNECT LIGHTNING PROTECTION SYSTEM TO BUILDING GROUND RING. CONDUCTOR TO BE BONDED TO THE TOP AND BOTTOM OF THE STEEL COLUMN AND RAN WITHIN 1" PVC CONDUIT WITHIN BUILDING INTERIOR.
 3. ALL METAL BODIES/STRUCTURE PROTRUDING FROM THE ROOF SHALL BE BONDED TO THE LIGHTNING PROTECTION SYSTEM.
 4. AIR TERMINALS ARE TO BE LOCATED AS SHOWN. THEY ARE TO BE A MAXIMUM OF 24" FROM THE ROOF EDGE AND PROJECT A MINIMUM OF 10" ABOVE THE PROTECTED EDGE. THE SPACING BETWEEN AIR TERMINALS ARE NOT TO EXCEED 20'. AIR TERMINALS THAT EXTEND 24" ABOVE THE PROTECTED EDGE ARE NOT TO EXCEED A SPACING GREATER THAN 25', EXCEPT FOR MID-ROOF AIR TERMINALS (50' MAX SPACING). VERIFY THAT THE SPACING BETWEEN DOWN CONDUCTORS IS IN COMPLIANCE WITH NFPA 780.
 5. ALL LIGHTNING PROTECTION CONDUCTORS SHALL BE CLASS 1 ALUMINUM.


LIGHTNING PROTECTION SYSTEM LEGEND

- AIR TERMINAL
- CRIMPED CONNECTION



ISOMER PROJECT GROUP
115 WELBORN ST., SUITE A
GREENVILLE, SC 29601
www.isomer.group

REV	DATE	REVISION & ISSUE HISTORY	DES	CHK	APP
0	24AUG23	ISSUED FOR CONSTRUCTION	KCB	NRR	JNC



SCALE AS NOTED



WAREHOUSE EXPANSION
TELLUS PRODUCTS, LLC.
37021 GATOR BLVD
BELLE GLADE, FL 33430



DOCUMENT TITLE
ELECTRICAL
LIGHTNING PROTECTION PLAN

PROJECT NO.	DRAWING NO.	REV.
TEL2305	EL-PLN-0004	0