



SCALE: NONE



- A. PROVIDE SHRADER FITTINGS IF NOT PROVIDED WITH CONDENSING UNIT. SHRADER FITTING SHALL BE INSTALLED DIRECTLY INTO PIPE; NO EXTENDED TUBES ALLOWED.
- B. ALL REFRIGERANT PIPING, ACCESSORIES, VALVES, ETC., SHALL BE INSTALLED IN COMPLIANCE WITH THE REFRIGERATION PIPING SCHEMATIC.
- C. INSTALL ARMAFLEX TYPE "AP" 3/4" THICK FOAM PLASTIC INSULATION ON ALL SECTION LINES FROM EACH CONDENSING UNIT TO THE AIR HANDLING UNIT COIL. ALL INSULATION SHALL BE INSTALLED WITH ARMSTRONG #520 ADHESIVE WITH 100% COVERAGE ON ALL JOINT JOINTS. INSULATION SHALL BE SLIPPED OVER PIPING IN ONE PIECE WITH NO LONGITUDINAL JOINTS.
- D. WHERE REFRIGERANT INSULATION IS INSTALLED EXPOSED OUTSIDE, IT SHALL BE PAINTED WITH TWO COATS OF PAINT, CONTAINING UV INHIBITORS, AND IN ACCORDANCE WITH THE INSULATION MANUFACTURER'S RECOMMENDATIONS. ARMSTRONG WP OR EQUAL.
- E. ALL REFRIGERANT PIPING, POWER AND CONTROL CONDUIT SHALL BE RUN ABOVE GRADE SUPPORTED WITH HOT-DIPPED GALVANIZED STRUT BOLTED TO THE GROUND EQUAL TO B-LINE.
- F. SLOPE ALL REFRIGERANT LINES TOWARD CONDENSING UNITS



SCALE: NONE



- A. PROVIDE A MINIMUM CLEARANCE OF 12" FROM TOP OF ROOFING TO TOP OF CURB.  
B. CENTRIFUGAL STYLE FAN SHOWN, UPBLAST TYPE SIMILAR

